



TÜRK STANDARDLARI ENSTİTÜSÜ
TURKISH STANDARDS INSTITUTION

CERTIFICATE OF CONSTANCY OF PERFORMANCE

1783-CPR-770

In compliance with Regulation (EU) 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Cable Type : XGB-F2

Reaction to Fire Performance: Cca, s2, d2, a1

(SCOPE IS AT THE ATTACHMENT)

placed on the market under the name or trade mark of

ÜNAL KABLO SANAYİ VE TİCARET A.Ş.
VELİMEŞE OSB. MAH. 247. SOK. NO:4/1 ERGENE / TEKİRDAĞ

and produced in the manufacturing plant

ÜNAL KABLO SANAYİ VE TİCARET A.Ş.
VELİMEŞE OSB. MAH. 247. SOK. NO:4/1 ERGENE / TEKİRDAĞ

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 50575: 2014 + A1: 2016

under system 1 + for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product .

This certificate was first issued on 15.12.2017 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Ankara, Rev. 0, 15.12.2017



Sezai DOĞAN
Direktifler Müdürü