

LICENCE

No. 20933 replaces No.19168

Issued to:
Applicant:
Unal Kablo San. Ve TIC. A.S.
Velimese Organize Sanayi Mah
247. Sokak No:4/1
59930 Ergene Tekirdag
Turkey

Licensee:

Unal Kablo San. Ve TIC. A.S. Velimese Organize Sanayi Mah 247. Sokak No:4/1 59930 Ergene Tekirdag Turkey

Product : cables for fixed wiring

Trade name(s) : UNAL CABLE, UNAL KABLO

Type(s)/model(s) : XGB

The product and any acceptable variation thereto is specified in the annex to this licence and the documents therein referred to.

SGS CEBEC hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard specified in annex
- an inspection of the production location
- a certification agreement with the number 1494

SGS CEBEC hereby grants the right to use the CEBEC certification mark
The CEBEC certification mark may be applied to the product as specified in
this licence for the duration of the CEBEC certification agreement and under the
conditions of the CEBEC certification agreement.

This licence is issued on: 17/08/2018

ir. C. Lana,

Certification Manager

cus

© Only integral publication of this certificate, including the annex, is allowed This certificate is only valid combined with the publication on the following web address; www.sgs.com/ee





SGSGSGSGS





ANNEX TO CEBEC LICENCE No. 20933 Page 1 of 3

SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

Product : cables for fixed wiring

Trade name(s) : UNAL CABLE, UNAL KABLO

Type(s)/Model(s) : XGB

description : cable with copper conductors, unarmoured

insulating material : XLPE insulated and sheathed with G type halogen free

compound

rated voltage Uo/U : 0.6/1 kV

Fire propagation : minimum Cca-s1,d2,a1

Additional information

Covered number of conductors (Round Type) and cross sections

1-core: 16 mm² to 300 mm² 2-core: 1.5 mm² to 25 mm² 3-core: 1.5 mm² to 35 mm² 4-core: 1.5 mm² to 35 mm² 5-core: 1.5 mm² to 25 mm²

TESTS

Test requirements

NBN HD 604:2016

Test results

The test results are laid down in test report ref. 604740.01

ANNEX TO CEBEC LICENCE No. 20933 Page 2 of 3



Conclusion

The examination proved that all test requirements were met.

Checked by, project leader : Luigi Zanutto - 17/08/2018

Department Manager, Product Certification

Certification Manager

· Silvio PikAs 12/08/2018

SGS Belgium NV-Division SGS CEBEC Business Riverside Park Bld Internationatelaan 55 Build. D B-4070 Brussels Tel.+32(0)2 556 00 20 Fax.+32(0)2 556 00 36 ANNEX TO CEBEC LICENCE No. 20933 Page 3 of 3



FACTORY LOCATION(S)

Unal Kablo San. Ve TIC. A.S. Velimese Organize Sanayi Mah 247. Sokak No:4/1 59930 Ergene Tekirdag Turkey