



**TÜRK STANDARDLARI ENSTİTÜSÜ**  
TURKISH STANDARDS INSTITUTION






Test  
TS EN ISO/IEC 17025  
AB-0001-T

**TSE DENEY VE KALİBRASYON MERKEZİ BAŞKANLIĞI**  
**ELEKTROTEKNİK LABORATUVARI GEBZE MÜDÜRLÜĞÜ**  
HEADSHIP OF TSE TEST AND CALIBRATION CENTER  
ELECTROTECHNICAL LABORATORY GEBZE DIRECTORATE

**CLASSIFICATION OF REACTION TO FIRE**  
**FOR ELECTRIC CABLES**  
**IN ACCORDANCE WITH EN 13501-6**

Sponsor/Manufacturer	:	ÜNAL KABLO SAN. VE TİC. LTD. ŞTİ.
Place of Manufacturer	:	Velimeşe Organize Sanayi Mah. 247.Şok. No:4/1 ERGENE / TEKİRDAĞ TÜRKİYE
Prepared by	:	<b>TSE Elektroteknik Laboratuvarı Gebze Müdürlüğü</b> Cumhuriyet Mah. 2258 Sokak Gebze / KOCAELİ - TÜRKİYE
Trade mark/ Type of Cable	:	ÜNAL KABLO / H07V-R
Product description	:	Class 2 Copper Conductor 450 /750 V PVC Insulated
Standard applied	:	TS EN 50575/A1:2016
Regulation	:	Construction Products Regulation (305/2011/EU)
Notified Body No	:	1783
Report Number	:	365219
Date of Issue	:	12.10.2017

**Reaction to Fire Class: *E<sub>ca</sub>***

Seal	Person in charge of tests	Approved by
		
13. / 10 / 2017	Bayram AY Electrical Engineer M.Sc	Güvenir Kaan ESEN Laboratory Director

**Note:** This classification document does not represent type approval or certification of the product. The classification assigned to the product in this report is appropriate to a declaration of conformity by the manufacturer within the context of system 3 attestation of conformity and CE marking under the Construction Products Regulation. The test laboratory has, therefore, played no part in sampling the product for the test, although it holds appropriate references, supplied by the manufacturer, to provide for traceability of the sample tested. This document consists of 2 pages. This report can't be partially copied and the unsigned copies are invalid.

TS EN 13501-6 04.2014  
LAB-D-2- FR-24 28.06.2017 Rev.0

[www.tse.org.tr](http://www.tse.org.tr) / Necatibey Cad. No: 112 Bakanlıklar - ANKARA / +90 312 416 62 00

Bu belge hiçbir suretle tahrif edilemez, kısmen veya okunmasını zorlaştıracak şekilde çoğaltılamaz, kazıntı ve silinti yapılamaz.  
This certificate cannot be altered, partially duplicated or creased for misunderstanding.