



TÜRK STANDARDLARI ENSTİTÜSÜ
TURKISH STANDARDS INSTITUTION






Test
TS EN ISO/IEC 17025
AB-0001-T

TSE DENEY VE KALİBRASYON MERKEZİ BAŞKANLIĞI
ELEKTROTEKNİK LABORATUVARI GEBZE MÜDÜRLÜĞÜ
HEADSHIP OF TSE TEST AND CALIBRATION CENTER
ELECTROTECHNICAL LABORATORY GEBZE DIRECTORATE

CLASSIFICATION OF REACTION TO FIRE
FOR ELECTRIC CABLES
IN ACCORDANCE WITH EN 13501-6

| | | |
|---------------------------|---|--|
| Sponsor/Manufacturer | : | ÜNAL KABLO SAN. VE TİC.LTD.ŞTİ. |
| Place of Manufacturer | : | Velimeşe Organize San. Mah. 247. Sok. No:4/1 Velimeşe / TEKİRDAĞ |
| Prepared by | : | TSE Elektroteknik Laboratuvarı Gebze Müdürlüğü Cumhuriyet Mah. 2258 Sokak Gebze / KOCAELİ - TÜRKİYE |
| Trade mark/ Type of Cable | : | ÜNAL KABLO LIY(St)Y |
| Product description | : | Signal and Control Cable - Multicore, conductor class 1, 300/500 V PVC insulation and sheath AL-PES TAPE |
| Standard applied | : | TS EN 50575/A1:2016 |
| Regulation | : | Construction Products Regulation (305/2011/EU) |
| Notified Body No | : | 1783 |
| Report Number | : | 365669 |
| Date of Issue | : | 12.10.2017 |

Reaction to Fire Class: *E_{ca}*

| | | |
|---|--|--|
| Seal  | Person in charge of tests  | Approved by  |
| 12./10/2017 | Münir ÖZKAYA Technician | Güvenir Kaan ESEN Laboratory Director |

Note: This classification document does not represent type approval or certification of the product. The classification assigned to the product in this report is appropriate to a declaration of conformity by the manufacturer within the context of system 3 attestation of conformity and CE marking under the Construction Products Regulation. The test laboratory has, therefore, played no part in sampling the product for the test, although it holds appropriate references, supplied by the manufacturer, to provide for traceability of the sample tested. This document consists of 2 pages. This report can't be partially copied and the unsigned copies are invalid.

TS EN 13501-6:04:2014
LAB-D-2- FR-24 28.06.2017 Rev.0

www.tse.org.tr / Necatibey Cad. No: 112 Bakanlıklar - ANKARA / +90 312 416 62 00

Bu belge hiçbir suretle tahrif edilemez, kısmen veya okunmasını zorlaştıracak şekilde çoğaltılamaz, kazıntı ve silinti yapılamaz.
This certificate cannot be altered, partially duplicated or creased for misunderstanding.