



REQUEST NUMBER: 239945

ELEKTROTEKNİK LABORATUVARI GEBZE MÜDÜRLÜĞÜ
Electrotechnical Laboratory (Gebze)

Yapı Malzemeleri Yönetmeliđi(305/2011/AB)
Construction Products Regulation(305/2011/EU)

ONAYLANMIŞ KURULUŞ : 1783
NOTIFIED BODY : 1783

TS EN 13501-6

YANGINA TEPKİ SINIFLANDIRMA RAPORU
REACTION TO FIRE CLASSIFICATION REPORT

Talep Eden

Applicant

Adresi

Address

: ÜNAL KABLO SAN. VE TİC. A.Ş.

: VELİMEŞE ORGANİZE SAN. MAH. 247. SOK. NO:4/1
ERGENE / TEKİRDAĞ

Name and address of Production Place

Markası, Ticari Modeli, Tipi

Trade Mark, Commercial Model, Type

: ÜNAL KABLO YMvK/N2XY/YXV/C2XY/XP00/CU/XLPE/PVC
U-1000 R2V/XV/RV

YANGINA TEPKİ SINIFI
REACTION TO FIRE CLASSIFICATION

E

Rapor Deđerlendirme Tarihi

Date of Issue

: 08.02.2024



BURCU PAZAR

DIRECTOR OF ELECTROTECHNICAL
LABORATORY (GEBZE) V.

Bu rapor 3 sayfadır ve kısmen çođaltılamaz.

This report is composed of 3 page and cannot be copied partially.

Adres: TSE Kalite Kampüsü Cumhuriyet Mah. 2258 Sok. No:10 H- Blok Gebze KOCAELİ TÜRKİYE

Tel: +90 2627231526

e-posta: elektroteknikgebze@tse.org.tr

web: www.tse.org.tr



1. INTRODUCTION

REQUEST NUMBER: 239945

This classification report defines the classification of cable below in accordance with the procedures given in TS EN 13501-6

2. DETAILS OF CLASSIFIED PRODUCT

2.1. General

Trade name, Type of cable	ÜNAL KABLO YMvK/N2XY/YXV/C2XY/XP00/CU/XLPE/PVC U-1000 R2V/XV/RV	
Tested cable and size and overall diameter	1- YMvK/N2XY/YXV/C2XY/XP00/CU/XLPE/PVC U-1000 R2V/XV/RV 2x1,50 mm ² 2- YMvK/N2XY/YXV/C2XY/XP00/CU/XLPE/PVC U-1000 R2V/XV/RV 4x240 mm ²	8,50 mm 62,45 mm

3. TEST REPORT AND RESULTS

3.1 Test Reports

Name of Laboratory	Test reports no and Date	Test methods
TSE Gebze Electrotechnical Laboratory	26350 / 01-24	(TS EN 60332-1-2/A1:2016 / A11: 2017)
TSE Gebze Electrotechnical Laboratory	26372 / 01-24	(TS EN 60332-1-2/A1:2016 / A11: 2017)

3.2 Test Results

Test method and type of cable	Parameter	No. of test	Test results	
			Continuous parameter	Compliance with parameters
YMvK/N2XY/YXV/C2XY/XP00/CU/XLPE/PVC U-1000 R2V/XV/RV 2x1,50 mm ² TS EN 60332-1-2/A11:2017	H (Vertical flame spread)	1	110 mm	≤ 425mm / Eca
YMvK/N2XY/YXV/C2XY/XP00/CU/XLPE/PVC U-1000 R2V/XV/RV 4x240 mm ² TS EN 60332-1-2/A11:2017	H (Vertical flame spread)	1	130 mm	≤ 425mm / Eca

4. CLASSIFICATION

Fire Behaviour	Smoke Production	Flaming Droplets	Acidity
Eca	-	-	-

Reaction to Fire Classification: **Eca**



REQUEST NUMBER: 239945

5. Field of Application

This classification is valid for the power cables listed below as determined in the extended application process according to CLC-FprTS 50576-2016.

Trade name	Cable Family	Outer diameter of cable	Reaction to Fire Classification
ÜNAL KABLO	YMvK/N2XY/YXV/C2XY/XP00/CU/XLPE/PVC U-1000 R2V/XV/RV	From 8,50 mm – to 76,06 mm	Eca

Prepared by

BAYRAM AY

TECHNICAL CHIEF

Approved by

BURCU PALA

DIRECTOR OF ELECTROTECHNICAL
LABORATORY (GEBZE) V.