



REQUEST NUMBER: 2024-270089

**ELEKTROTEKNİK LABORATUVARI GEBZE MÜDÜRLÜĞÜ**  
*Electrotechnical Laboratory (Gebze)*

Yapı Malzemeleri Yönetmeliği(305/2011/AB)  
Construction Products Regulation(305/2011/EU)

**ONAYLANMIŞ KURULUŞ : 1783**  
NOTIFIED BODY : 1783

TS EN 13501-6

**YANGINA TEPKİ SINIFLANDIRMA RAPORU**  
*REACTION TO FIRE CLASSIFICATION REPORT*

**Talep Eden**

Applicant

: ÜNAL KABLO SAN. VE TİC. A.Ş.

**Adresi**

Address

: VELİMEŞE ORGANİZE SAN. MAH. 247. SOK. NO:4/1  
ERGENE / TEKİRDAĞ

Name and address of Production Place

**Markası,Ticari Modeli,Tipi**

Trade Mark, Commercial Model,Type

: ÜNAL KABLO F/UTP

**YANGINA TEPKİ SINIFI**  
*REACTION TO FIRE CLASSIFICATION*

**E**

**Rapor Değerlendirme Tarihi**

Date of Issue

: 07.11.2024



BURCU PALA

DIRECTOR OF ELECTROTECHNICAL  
LABORATORY (GEBZE) V.

Bu rapor 3 sayfadır ve kısmen çoğaltılamaz.

This report is composed of 3 page and cannot be copied partially.

Adres: TSE Kalite Kampüsü Cumhuriyet Mah. 2258 Sok. No:10 H- Blok Gebze KOCAELİ TÜRKİYE

Tel: +90 2627231526

e-posta: elektroteknikgebze@tse.org.tr

web: [www.tse.org.tr](http://www.tse.org.tr)



## 1. INTRODUCTION

REQUEST NUMBER:2024- 2024-270089

This classification report defines the classification of cable below in accordance with the procedures given in TS EN 13501-6

## 2. DETAILS OF CLASSIFIED PRODUCT

### 2.1. General

Trade name, Type of cable	ÜNAL KABLO F/UTP DATA KABLOSU	
Tested cable and size and overall diameter	1- Cat 5e F/UTP DATA KABLOSU 2- Cat 6 F/UTP DATA KABLOSU	5,50 mm 6,65 mm

## 3. TEST REPORT AND RESULTS

### 3.1 Test Reports

Name of Laboratory	Test reports no and Date	Test methods
TSE Gebze Electrotechnical Laboratory	365481 / 11-24	( TS EN 60332-1-2/A1:2016 / A11: 2017)
TSE Gebze Electrotechnical Laboratory	365507 / 11-24	( TS EN 60332-1-2/A1:2016 / A11: 2017)

### 3.2 Test Results

Test method and type of cable	Parameter	No. of test	Test results	
			Continuous parameter	Compliance with parameters
Cat 5e F/UTP DATA KABLOSU TS EN 60332-1-2/A11:2017	H (Vertical flame spread)	1	140 mm	≤ 425mm / Eca
Cat 6 F/UTP DATA KABLOSU TS EN 60332-1-2/A11:2017	H (Vertical flame spread)	1	120 mm	≤ 425mm / Eca

## 4. CLASSIFICATION

Fire Behaviour	Smoke Production	Flaming Droplets	Acidity
Eca	-	-	-

Reaction to Fire Classification: **Eca**



REQUEST NUMBER: 2024-270089

## 5. Field of Application

This classification is valid for the power cables listed below as determined in the extended application process according to CLC-FprTS 50576-2016.

Trade name	Cable Family	Outer diameter of cable	Reaction to Fire Classification
ÜNAL KABLO	F/UTP	From 5,50 mm – to 8,32 mm	Eca

Prepared by

MÜNİR ÖZKAYA

TEST STAFF

Approved by

BURCU BALA

DIRECTOR OF ELECTROTECHNICAL  
LABORATORY (GEBZE) V.