

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHJECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1220311

Product: Electrical cables with thermoplastic PVC insulation and sheath, fixed wiring

Type: CYKY-CYKYLo

Rating: (2-5) x (1,5-10) mm² (CYKY),
(2-3) x (1,5-4) mm² (CYKYLo), 450/750 V

Ordering firm: ÜNAL KABLO SANAYI VE TICARET A.Ş.
Velimeşe O.S.B Mah. 247 Sokak No: 4/1, Çorlu-Tekirdağ, Turkey

Manufacturer: ÜNAL KABLO SANAYI VE TICARET A.Ş.
Velimeşe O.S.B Mah. 247 Sokak No: 4/1, Çorlu-Tekirdağ, Turkey

Factories: ÜNAL KABLO SANAYI VE TICARET A.Ş.
Velimeşe O.S.B Mah. 247 Sokak No: 4/1, Çorlu-Tekirdağ, Turkey

Trade mark:

The test results are stated in the test-report No.: 221417-01/01 of: 27.06.2022

A sample of the product was found to be in conformity with:
ČSN 34 7411:2014

Other data:

The validity of the certificate is limited to: 28.06.2025

29.06.2022

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



221417-01