



TÜRK STANDARDLARI ENSTİTÜSÜ
TURKISH STANDARDS INSTITUTION



Test
TS EN ISO/IEC 17025
AB-0001-T




TSE DENEY VE KALİBRASYON MERKEZİ BAŞKANLIĞI
ELEKTROTEKNİK LABORATUVARI GEBZE MÜDÜRLÜĞÜ
HEADSHIP OF TSE TEST AND CALIBRATION CENTER
ELECTROTECHNICAL LABORATORY GEBZE DIRECTORATE

CLASSIFICATION OF REACTION TO FIRE
FOR ELECTRIC CABLES
IN ACCORDANCE WITH EN 13501-6

Sponsor name and adress	:	ÜNAL KABLO SAN. VE TİC.LTD.ŞTİ.
Trade mark	:	ÜNAL KABLO
Model	:	H05V-U
Product description	:	Energy Cable
Standard applied	:	TS EN 50575/A1:2016
Regulation	:	Construction Products Regulation (305/2011/EU)
Notified Body No	:	1783
Report Number	:	364712
Date of Issue	:	09.10.2017

Reaction to Fire Class: *E_{ca}*

1783

Seal	Person in charge of tests	Approved by
		
23/10/2017	Mücahit TEKEL Technical Teacher	Güvenir Kaan ESEN Laboratory Director

Note: This classification document does not represent type approval or certification of the product. The classification assigned to the product in this report is appropriate to a declaration of conformity by the manufacturer within the context of system 3 attestation of conformity and CE marking under the Construction Products Regulation. The test laboratory has, therefore, played no part in sampling the product for the test, although it holds appropriate references, supplied by the manufacturer, to provide for traceability of the samples tested. This document consists of 2 pages. This report can't be partially copied and the unsigned copies are invalid.

TS EN 13501-6 04.2014
LAB-D-2- FR-24 28.06.2017 Rev.0

www.tse.org.tr / Necatibey Cad. No: 112 Bakanlıklar - ANKARA / +90 312 416 62 00

Bu belge hiçbir suretle tahrif edilemez, kısmen veya okunmasını zorlaştıracak şekilde çoğaltılamaz, kazıntı ve silinti yapılamaz.
This certificate cannot be altered, partially duplicated or creased for misunderstanding.