



**TÜRK STANDARDLARI ENSTİTÜSÜ**  
TURKISH STANDARDS INSTITUTION

**CERTIFICATE OF CONSTANCY OF PERFORMANCE**

**1783-CPR-1391**

In compliance with Regulation (EU) 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

**Cable Type : XGB (Single core)**

**Reaction to Fire Performance: B2<sub>ca</sub>- s1, d2, a1**

*Cables used in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke*

**(SCOPE IS AT THE ATTACHMENT)**

placed on the market under the name or trade mark of

**ÜNAL KABLO SANAYİ VE TİCARET ANONİM ŞİRKETİ**  
**ORUÇREİS MAH. TEKSTİLKENT CAD. TEKSTİLKENT BLOK B NO:12 A /154 ESENLER İSTANBUL**

and produced in the manufacturing plant

**ÜNAL KABLO SANAYİ VE TİCARET ANONİM ŞİRKETİ**  
**VELİMEŞE ORGANİZE SANAYİ MAHALLESİ 247. SOKAK NO:4/1 ERGENE/TEKİRDAĞ**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

**EN 50575: 2014 + A1: 2016**

under system 1 + for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

**constancy of performance of the construction product .**

This certificate was first issued on 21.12.2023 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Ankara, Rev. 01/21.12.2023



Ali Fuat ÇOLAK  
Deputy Director of Directives



**TÜRK STANDARDLARI ENSTİTÜSÜ**  
TURKISH STANDARDS INSTITUTION

ATTACHMENT OF THE CERTIFICATE OF CONSTANCY OF PERFORMANCE

**PRODUCT DESCRIPTION:**

Designation of cable family	XGB (Single core)
Rated voltage	0,6/1 kV

**RELEVANT CONSTRUCTIONAL INFORMATION:**

Conductor design	Round
Conductor class	2
Number of cores	Single core
Screen	Does not include
Armour	Does not include

**ELECTRIC CABLES-EXTENDED APPLICATION OF TEST RESULTS FOR REACTION TO FIRE  
TS CLC TS 50576:**

Covered field
<input type="checkbox"/> Armoured
<input type="checkbox"/> Unarmoured multicore
<input checked="" type="checkbox"/> Single core sheathed
<input type="checkbox"/> Single core unsheathed
<input type="checkbox"/> Cable family including diameter $\leq 5$ mm

**CROSS-SECTIONS IN THE SCOPE:**

Number of cores	Cross-section mm <sup>2</sup>
1	10 to 240

**CABLE PARAMETER RANGE**

$$\chi = 2 - 11$$

**OUTER DIAMETER RANGE:**

$$D = 8,5 \text{ mm} - 26,6 \text{ mm}$$



Attachment of the Certificate of Constancy of Performance, 1783-CPR-1391.